

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-0476:107 Page 1 of 1

**CATEGORY:** Control Units (Non High-Rise)

**LISTEE:** Harrington Signal, 2519 4th Avenue, Moline, IL 61265  
Contact: Andrew Keller (309) 762-0731

**DESIGN:** Model HS-2200 and HS-2400 control units. Local, central station, auxiliary, remote station and proprietary. Noncoded, automatic, manual, waterflow and sprinkler supervisory service.

When the HS-2200/2400 incorporate the Model CAM Class A bell module, each of the Style Y signaling circuits can be configured as a Style Z signaling circuit. Model MBM master box module may be installed within the control unit or in separate Model MBM-B enclosure (CSFM Listing No. 7300-0476:109).

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number electrical rating and UL label.

**APPROVAL:** Listed as fire alarm control units when use in conjunction with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

6-07-94



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager